

2021 AUG 23 PM 2: 19



MISSISSIPPI STATE DEPARTMENT OF HEALTH

**2020 CERTIFICATION****Consumer Confidence Report (CCR)**City of Columbia

Public Water System Name

0460003

List PWS ID #s for all Community Water Systems included in this CCR

The Federal Safe Drinking Water Act (SDWA) requires each Community Public Water System (PWS) to develop and distribute a Consumer Confidence Report (CCR) to its customers each year. Depending on the population served by the PWS, this CCR must be mailed or delivered to the customers, published in a newspaper of local circulation, or provided to the customers upon request. Make sure you follow the proper procedures when distributing the CCR.

**CCR DISTRIBUTION (Check all boxes that apply.)****INDIRECT DELIVERY METHODS (Attach copy of publication, water bill or other)****DATE ISSUED**☐ Advertisement in local paper (Attach copy of advertisement)☐ On water bills (Attach copy of bill)☐ Email message (Email the message to the address below)☐ Other \_\_\_\_\_**DIRECT DELIVERY METHOD (Attach copy of publication, water bill or other)****DATE ISSUED**☐ Distributed via U. S. Postal Mail☐ Distributed via E-Mail as a URL (Provide Direct URL): \_\_\_\_\_☐ Distributed via E-Mail as an attachment☐ Distributed via E-Mail as text within the body of email message☐ Published in local newspaper (attach copy of published CCR or proof of publication)5/27/21☒ Posted in public places (attach list of locations) CITY Hall5/20/21☒ Posted online at the following address (Provide Direct URL): https://msdwa.org/2020CCR/columbia.pdf 5/20/21**CERTIFICATION**

I hereby certify that the CCR has been distributed to the customers of this public water system in the form and manner identified above and that I used distribution methods allowed by the SDWA. I further certify that the information included in this CCR is true and correct and is consistent with the water quality monitoring data provided to the PWS officials by the MSDH, Bureau of Public Water Supply.

Michael McDaniel

Name

Operator

Title

5/21/21

Date

**SUBMISSION OPTIONS (Select one method ONLY)**

You must email, fax (not preferred), or mail a copy of the CCR and Certification to the MSDH.

Mail: (U.S. Postal Service)

MSDH, Bureau of Public Water Supply

P.O. Box 1700

Jackson, MS 39215

Email: [water.reports@msdh.ms.gov](mailto:water.reports@msdh.ms.gov)

Fax: (601) 576-7800

(NOT PREFERRED)

**CCR DEADLINE TO MSDH & CUSTOMERS: BY JULY 1, 2021**

2020 Annual Drinking Water Quality Report  
City of Columbia  
PWS#: 0460003  
May 2021

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from wells drawing from the Miocene Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the City of Columbia have received a lower ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Michael McDaniel at 601.736.8201. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 4:00 PM at the City Hall.

We routinely monitor for con contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS								
Contaminant	Violation Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL/MRDL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>								
10. Barium	N	2019*	.0416	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

13. Chromium	N	2019*	.9	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
14. Copper	N	2018*	.2	0	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
16. Fluoride**	N	2019*	.121	No Range	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
17. Lead	N	2018*	8	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
19. Nitrate (as Nitrogen)	N	2020	.22	No Range	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

### Disinfection By-Products

81. HAA5	N	2020	3	No Range	ppb	0	60	By-Product of drinking water disinfection.
Chlorine	N	2020	1.3	0 – 1.5	ppm	0	MRDL = 4	Water additive used to control microbes

\* Most recent sample. No sample required for 2019.

\*\* Fluoride level is routinely adjusted to the MS State Dept of Health's recommended level of 0.6 - 1.2 mg/l.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies", the CITY OF COLUMBIA is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 4. The percentage of fluoride samples collected in the previous calendar year that was within the optimal range of 0.6-1.2 ppm was 33%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1.800.426.4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline 1.800.426.4791.

The City of Columbia works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

## PROOF OF PUBLICATION

### THE STATE OF MISSISSIPPI COUNTY OF MARION

Personally appeared before me, the undersigned Notary Public, in and for the County and State aforesaid, **Tracey McNeese** who being by me and duly sworn, states on oath that she is Legal Clerk of the Columbian-Progress, a newspaper published in the City of Columbia, State and County, aforesaid, and that the publication of the notice, a copy of which is hereto attached, has been made in said paper 1 time(s), as follows:

In Vol. 119 No. 40 Date 27 day of May, 2021

In Vol. 119 No. \_\_\_\_\_ Date \_\_\_\_\_ day of \_\_\_\_\_, 2021

In Vol. 119 No. \_\_\_\_\_ Date \_\_\_\_\_ day of \_\_\_\_\_, 2021

In Vol. 119 No. \_\_\_\_\_ Date \_\_\_\_\_ day of \_\_\_\_\_, 2021

Signed

Tracey McNeese

Tracey McNeese

Sworn to and subscribed before me, this 27th day of May, 2021.

Bonnie Hudson  
Bonnie Hudson, Notary Public  
ID # 79251  
BONNIE G. HUDSON  
Commission Expires  
Nov. 3, 2021  
MARION COUNTY

No. words 314 at 11.50 Total \$ 483<sup>00</sup>

Proof of Publication ..... \$3.00

Total Cost ..... \$ 486<sup>00</sup>

THIS IS NOT A STATEMENT

Attached

## rist &amp; Gifts

Over 26 years  
of floral service

FLORIST

Sat. 8:00 - 5:00

ays

d

We supply Marion  
and surrounding  
counties.Guaranteed Delivery  
• 8 of the Best Floral  
Designers in the South

601-736-3530

## 2020 Annual Drinking Water Quality Report

City of Columbia

PWS#: 0460003

May 2021

We're pleased to present to you this year's Annual Quality Water. This report is designed to inform you about the quality water and we deliver to you day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to providing you with information because informed customers are our best allies. Our water source is from Wells drawing from Moccasin Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identify potential sources of contamination. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The Wells for the City of Columbia have received a lower ranking in terms of susceptibility to contamination.

If you have any questions about this report or concerning your water utility, please contact Michael McDowell at 601.736.3201. We want our valued customers to be informed about their water utility. If you want to learn more, please join us at any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 4:00 PM at the City Hall.

We routinely monitor for contaminants in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that were detected during the period of January 1st to December 31st, 2020. In cases where monitoring wasn't required in 2020, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity. Microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential use; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Action Level** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL)** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal (MCLG)** - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL)** - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary to control microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG)** - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Parts per million (ppm) or Milligrams per liter (mg/L)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter (µg/L)** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

TEST RESULTS									
Contaminant	Monitor Type	Date Collected	Level Detected	Range of Detection or of Sampling Frequency (MCLG/MCL/MDL)	Unit	Limit	Remarks	MCL	Level Exceeded Contamination
<b>Inorganic Contaminants</b>									
13. Arsenic	N	2019	2416	No Range	ppm	10	Discharge from steel and pulp mills, erosion of natural deposits	10	
14. Chromium	N	2019	3	No Range	ppm	100	Discharge from steel and pulp mills, erosion of natural deposits	100	
15. Copper	N	2019	3	0	ppm	1.3	Corrosion of household plumbing systems, erosion of natural deposits, discharge from steel and pulp mills	1.3	
16. Fluoride	N	2019	121	No Range	ppm	4	Discharge from natural deposits, water additive which promotes strong teeth, discharge from fertilizer and aluminum facilities	4	
17. Lead	N	2019	8	0	ppm	0.01	Corrosion of household plumbing systems, erosion of natural deposits, discharge from steel and pulp mills	0.01	
18. Nitrate (as Nitrogen)	N	2020	22	No Range	ppm	10	Punch from fertilizer use, leaching from waste, fertilizers, erosion of natural deposits	10	
<b>Disinfection By-Products</b>									
21. HAAs	N	2020	3	No Range	ppm	0	By-product of drinking water disinfection	0	
22. Trihalomethanes	N	2020	1.3	0-1.5	ppm	0.1	Trihalomethanes used to control disinfection	0.1	

\* Most recent data: No sample required for 2019.

\*\* Fluoride level is routinely adjusted to the MCL State Dept of Health's recommended level of 0.6 - 1.2 mg/L.

We are required to monitor your drinking water for specific contaminants on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards, in an effort to ensure systems comply with monitoring requirements. MCLs are not a guarantee of water quality, samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our water system is responsible for providing high quality drinking water, but cannot control the safety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/lead>. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.575.7567 if you wish to have your water tested.

To comply with the "Regulation Governing Fluoridation of Community Water Supplies," the CITY OF COLUMBIA is required to report certain results pertaining to fluoridation of our water system. The number of months in the previous calendar year in which average fluoride sample results were within the optimal range of 0.6-1.2 ppm was 32%.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be minerals, organic or inorganic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4761.

Some people may be more susceptible to contaminants in drinking water than the general population. Seniors, compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline: 1-800-426-4761.

The City of Columbia works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water resources, which are the heart of our community, our way of life and our children's future.